

ALERT

SEVERE CLOGGING & BACKUP

MAIN SEWER LINE – Townhouses II*

*(Section beginning at 277/278 Paseo Seco and running North)

Discovered when homeowner's toilet backed up into shower.
Wastewater Management called and discovered
large ball of wipes / thick paper fragments clogging main line.

Wastewater Management has put this section of sewer line on 6 – 9 month maintenance/flush schedule,
and made the following recommendations:

Flush Toilet Paper Only

Do Not Flush

Wipes

Kleenex

“Flushable” Cleaning Products

(Packaging marked “Flushable” is often not biodegradable)

Resources:

Pima County Wastewater Management – (520) 724-3400 Calls answered 24/7

Office Hours – 7am to 5 pm

After Hours Calls – Forwarded to Operational Control Center